13:48 August 14, 2012



City of Park Hills #9 Bennett Street Park Hills, Mo. 63601 (573) 431-3577

Page 1 of 1 Untitled

CERTIFICATE OF OCCUPANCY

This Certificate of Occupancy is issued to **David Hurst** for the property located at

504 Bass within the City of Park Hills, Missouri.

The above named structure has been inspected and found in compliance,

with Chapter 505, Housing Code of the City of Park Hills, Missouri.

Date: 08/14/12

Authorized Signature

This form is to be taken to the Park Hills Water Department.



City of Park Hills # 9 Bennett Street Park Hills, Mo. 63601 573-431-3577

Page 3 of 3 504Bass-0712

Repair Summary

Repair - Minor Repairs Required

Building Exterior

1. Decks Install a graspable handrail down rear deck steps, maximum size, no larger than 2 lnches in diameter. Corrected

Laundry / Utility

2. Electrical Install GFCI protection to outlet above washer hookup. Outlets are required to be grounded if residence is served by a breaker box. Residences served by fuse systems may install GFCI outlets without a ground but all GFCI and GFCI protected outlets must be labeled, "No Equipment Ground". Corrected

Water Heater

3. Location Utility Corrected

- 4. Electrical Install exposed wiring to water heater in an approved U.L. conduit and terminate conduit on water heater with proper conduit fitting. Corrected
 - Master Bath
- 5. Electrical Install G.F.C.I protection to all 110 volt outlets that are within six (6) feet of water. Outlets are required to be grounded if residence is served by a breaker box. Residences served by fuse systems may install GFCI outlets without a ground but all GFCI and GFCI protected outlets must be labeled, "No Equipment Ground". Corrected